

Electric Outages Lewes BPW

| Month | Date | Circuit | Customers Interrupted | Duration | Cause | Percent System Reliability |
|---------------|---------|---------|-----------------------|----------|--------------------|----------------------------|
| January 2017 | 1/23/17 | 3 | 5 | 25 | Wind | 99.99956% |
| February 2017 | 2/18/17 | 3 | 4 | 120 | Equipment damage | 99.99969% |
| | 2/20/17 | 3 | 5 | 60 | Electrical failure | |
| March 2017 | 3/10/17 | 1 | 3 | 30 | Squirrel | 99.99881% |
| | 3/11/17 | 1 | 2 | 60 | Squirrel | |
| | 3/17/17 | 3 | 1 | 120 | Equipment damage | |
| April 2017 | 4/14/17 | 1 | 3 | 60 | Squirrel | 99.96995% |
| | 4/20/17 | 1 | 3 | 50 | Equipment worn out | |
| | 4/27/17 | 3 | 3 | 120 | Equipment Damage | |
| | 4/30/17 | 3 | 2 | 60 | Equipment Damage | |
| May 2017 | 5/2/17 | 2 | 5 | 30 | Equipment Damage | 99.99982% |
| | 5/17/17 | 2 | 1 | 45 | Equipment Damage | |
| | 5/17/17 | 2 | 4 | 45 | Equipment worn out | |
| | 5/19/17 | 2 | 1 | 45 | Equipment Damage | |
| | 5/23/17 | 1 | 5 | 15 | Squirrel | |

